

Reason for false alarm			2018/19	2019/20	2020/21	2021/22	2022/23
Total			-	-	-	-	-
Malicious	Total		-	-	-	-	-
Malicious	By phone		98	71	66	47	76
Malicious	By phone, Call NOT challenged		3	3	1	5	6
Malicious	Activation of fire call point/alarm		100	111	45	109	78
Malicious	Bonfire		1	2	2	2	2
Malicious	Other		2	2	1	17	-
Malicious	Missing data		-	-	-	-	-
Due to apparatus	Total		-	-	-	-	-
Due to apparatus	Human	Total	-	-	-	-	-
Due to apparatus	Human	Accidentally/carelessly set off	211	244	204	273	258
Due to apparatus	Human	Testing	102	120	125	173	171
Due to apparatus	Human	Smoking	70	96	73	77	111
Due to apparatus	Human	Cooking/burnt toast	651	582	610	652	667
Due to apparatus	Human	Other	86	75	126	103	104
Due to apparatus	Animal	Total	-	-	-	-	-
Due to apparatus	Animal	Accidentally/carelessly set off	-	-	-	1	2
Due to apparatus	Animal	Other	-	4	1	2	2
Due to apparatus	System: Smoke alarm	Total	-	-	-	-	-
Due to apparatus	System: Smoke alarm	Poor maintenance	15	21	21	32	24
Due to apparatus	System: Smoke alarm	Faulty	397	422	460	501	447
Due to apparatus	System: Smoke alarm	Damaged	7	11	7	4	5
Due to apparatus	System: Smoke alarm	Incorrect positioning	11	14	17	17	17
Due to apparatus	System: Smoke alarm	Unsuitable equipment	3	10	5	5	1
Due to apparatus	System: Smoke alarm	Water intrusion	10	21	18	13	21
Due to apparatus	System: Smoke alarm	Other	120	117	132	115	117
Due to apparatus	System: Sprinkler	Total	-	-	-	-	-
Due to apparatus	System: Sprinkler	Poor maintenance	-	1	5	6	-
Due to apparatus	System: Sprinkler	Faulty	12	11	6	8	5
Due to apparatus	System: Sprinkler	Damaged	2	4	1	1	-
Due to apparatus	System: Sprinkler	Incorrect positioning	-	-	-	-	-
Due to apparatus	System: Sprinkler	Unsuitable equipment	1	4	-	-	-
Due to apparatus	System: Sprinkler	Water intrusion	-	2	-	-	3
Due to apparatus	System: Sprinkler	Other	1	5	4	1	2
Due to apparatus	System: Heat	Total	-	-	-	-	-
Due to apparatus	System: Heat	Poor maintenance	1	2	7	2	3
Due to apparatus	System: Heat	Faulty	13	20	19	20	15
Due to apparatus	System: Heat	Damaged	-	-	-	-	-
Due to apparatus	System: Heat	Incorrect positioning	6	3	5	4	5
Due to apparatus	System: Heat	Unsuitable equipment	2	-	3	-	-
Due to apparatus	System: Heat	Water intrusion	1	1	3	2	2
Due to apparatus	System: Heat	Other	2	5	6	6	5
Due to apparatus	System: Flame	Total	-	-	-	-	-
Due to apparatus	System: Flame	Poor maintenance	-	-	-	-	-
Due to apparatus	System: Flame	Faulty	2	1	2	5	1
Due to apparatus	System: Flame	Damaged	-	-	-	-	-
Due to apparatus	System: Flame	Incorrect positioning	-	-	-	-	-
Due to apparatus	System: Flame	Unsuitable equipment	-	3	-	-	-
Due to apparatus	System: Flame	Water intrusion	-	1	-	-	1
Due to apparatus	System: Flame	Other	1	1	-	-	-
Due to apparatus	System: Other	Total	-	-	-	-	-
Due to apparatus	System: Other	Poor maintenance	11	16	18	10	15
Due to apparatus	System: Other	Faulty	230	243	210	285	225
Due to apparatus	System: Other	Damaged	12	9	8	5	6
Due to apparatus	System: Other	Incorrect positioning	3	4	3	7	8
Due to apparatus	System: Other	Unsuitable equipment	3	3	3	3	1
Due to apparatus	System: Other	Water intrusion	5	16	14	19	19
Due to apparatus	System: Other	Other	64	75	79	82	75
Due to apparatus	Contaminants	Total	-	-	-	-	-
Due to apparatus	Contaminants	Thrips	29	29	17	18	15
Due to apparatus	Contaminants	Steam	37	38	51	66	48
Due to apparatus	Contaminants	Chemicals/aerosols	27	28	32	17	24
Due to apparatus	Contaminants	Dust	150	94	121	180	150
Due to apparatus	Contaminants	Smoke Cloak	1	4	8	6	10
Due to apparatus	Contaminants	Other	18	19	26	24	12
Due to apparatus	External factors	Total	-	-	-	-	-
Due to apparatus	External factors	Power surge	9	11	3	3	10
Due to apparatus	External factors	Storm	1	3	1	1	4
Due to apparatus	External factors	Water supplies -sprinklers only	-	1	1	-	-
Due to apparatus	External factors	Bonfire	2	1	1	-	-
Due to apparatus	External factors	Smoke from elsewhere (not at location)	3	3	2	-	3
Due to apparatus	External factors	Other	12	5	7	15	13
Due to apparatus	Unknown		149	140	148	173	186
Due to apparatus	Missing data		-	-	-	-	-
Good intent	Total		-	-	-	-	-
Good intent	Smell of burning	Total	-	-	-	-	-
Good intent	Smell of burning	Overheating light/fitting	24	16	19	36	19
Good intent	Smell of burning	Overheating appliance	59	52	52	65	53
Good intent	Smell of burning	Fire elsewhere (not at location)	66	69	51	45	113
Good intent	Smell of burning	Vehicle	125	103	77	107	131
Good intent	Burnt toast/food	Total	-	-	-	-	-
Good intent	Burnt toast/food	Toaster/toast	208	229	237	261	173
Good intent	Burnt toast/food	Other cooking	384	405	379	359	343
Good intent	Burnt toast/food	BBQ	53	36	49	34	54
Good intent	Burnt toast/food	Bonfire	982	873	1040	829	823
Good intent	Smoke/condensation	Total	-	-	-	-	-
Good intent	Smoke/condensation	Controlled burning	101	96	100	109	124
Good intent	Smoke/condensation	Air conditioning	3	4	3	3	2
Good intent	Smoke/condensation	Steam	139	171	136	144	117
Good intent	Smoke/condensation	Smoking chimney	30	32	34	27	26
Good intent	Smoke/condensation	Fumes/heat haze	121	108	102	92	120
Good intent	Smoke/condensation	Water intrusion	12	10	11	8	9
Good intent	Other	Total	-	-	-	-	-
Good intent	Other	Reflected light/sun-light	16	17	10	10	11
Good intent	Other	Reported incident/Location not found	179	184	27	154	58
Good intent	Other	Carbon monoxide alarm	68	47	59	52	40
Good intent	Other	Security/intruder alarm	52	46	41	29	38
Good intent	Other	Other	635	559	467	589	577
Good intent	Missing data		-	-	-	-	-
Good intent	Special Service	Not Required	54	276	241	317	285